



February 27, 2015

**CITY OF RANCHO MIRAGE
ADDENDUM NO. 2**

**REQUEST FOR PROPOSALS FOR
CITY HALL HVAC COOLING TOWER REPLACEMENT**

TO ALL PROSPECTIVE BIDDERS:

The following changes, corrections, and clarifications shall be made a part of the Request For Proposals (“RFP”) and contract documents:

The following is hereby added to the section of the RFP titled **Scope of Services, Section A. Cooling Tower Requirements/Specifications, 3. Furnish and Replacement of Existing Condensed Water Pumps.**

g. Y Strainer/Filter: The current configuration of this filter is inaccessible for servicing. If this Y Strainer/Filter is reused then it must be relocated and positioned to allow routine servicing. If the proposed new cooling tower includes a new Y Strainer/filter then it must be positioned to allow access for routine serving. (See attached photo.)

GENERAL INSTRUCTIONS:

This Addendum constitutes an integral part of the RFP and shall be read in conjunction with the RFP. Where inconsistent with the RFP, this Addendum shall govern. It is the responsibility of all respondents to the RFP to conform to this Addendum. Unless specifically changed herein, all other requirements, terms and conditions of the RFP remain unchanged.



*****END ADDENDUM NO. 2*****

All other RFP requirements stay the same.

ALL PROPOSERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM NO. 2 AND ITS ATTACHMENTS BY SIGNING THE ATTACHED RECEIPT SHEET AND SUBMITTING THE SIGNED SHEET WITH THEIR BID PROPOSAL. FAILURE TO COMPLY MAY BE CAUSE TO CONSIDER THE BID PROPOSAL NON-RESPONSIVE.

Sincerely,

Valerie Walthou

WJO William Oppenheim
Facilities & Fleet Maintenance Manager

ADDENDUM RECEIPT SHEET

ADDENDUM NO. 2

**TO: CITY OF RANCHO MIRAGE
FACILITIES & FLEET MAINTENANCE MANAGER**

**RE: REQUEST FOR PROPOSALS FOR CITY HALL HVAC COOLING TOWER
REPLACEMENT**

Receipt of Addendum No. 2 and its attachments is hereby acknowledged.

Bidder

Signature

Date

**THIS PAGE TO BE ATTACHED TO YOUR BID.
FAILURE TO ATTACH THIS PAGE TO YOUR BID MAY BE
CAUSE TO CONSIDER YOUR BID PROPOSAL
NON-RESPONSIVE**